

# Appendix I

## Laboratory Results for Water Quality



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.  
Tel: (852) 2676 2983 Fax: (852) 2676 2860  
e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020025  
DATE OF ISSUE : 03 February 2017  
PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 01 Feb 2017  
Received Date : 01 Feb 2017  
Testing Period : 01 Feb 2017 to 03 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 1/2/2017	001	Total Suspended Solids	2.8	mg/L
LT3 I5-2 1/2/2017	002	Total Suspended Solids	<2.5	mg/L
LT3 C3a-1 1/2/2017	003	Total Suspended Solids	11	mg/L
LT3 C3a-2 1/2/2017	004	Total Suspended Solids	11	mg/L
LT3 C3b-1 1/2/2017	005	Total Suspended Solids	3.6	mg/L
LT3 C3b-2 1/2/2017	006	Total Suspended Solids	4.1	mg/L


--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

  
Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO.	: N17020109	PAGE	: Page 1 of 1
DATE OF ISSUE	: 07 February 2017		

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 03 Feb 2017  
Received Date : 03 Feb 2017  
Testing Period : 03 Feb 2017 to 07 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 3/2/2017	001	Total Suspended Solids	<2.5	mg/L
LT3 I5-2 3/2/2017	002	Total Suspended Solids	2.8	mg/L
LT3 C3a-1 3/2/2017	003	Total Suspended Solids	9.1	mg/L
LT3 C3a-2 3/2/2017	004	Total Suspended Solids	17	mg/L
LT3 C3b-1 3/2/2017	005	Total Suspended Solids	3.7	mg/L
LT3 C3b-2 3/2/2017	006	Total Suspended Solids	3.6	mg/L


--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

  
Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020134  
DATE OF ISSUE : 08 February 2017  
PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 06 Feb 2017  
Received Date : 06 Feb 2017  
Testing Period : 06 Feb 2017 to 08 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 6/2/2017	001	Total Suspended Solids	<2.5	mg/L
LT3 I5-2 6/2/2017	002	Total Suspended Solids	<2.5	mg/L
LT3 C3a-1 6/2/2017	003	Total Suspended Solids	16	mg/L
LT3 C3a-2 6/2/2017	004	Total Suspended Solids	35	mg/L
LT3 C3b-1 6/2/2017	005	Total Suspended Solids	5.7	mg/L
LT3 C3b-2 6/2/2017	006	Total Suspended Solids	5.9	mg/L


--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

  
Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020167  
DATE OF ISSUE : 10 February 2017 PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 08 Feb 2017  
Received Date : 08 Feb 2017  
Testing Period : 08 Feb 2017 to 10 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 8/2/2017	001	Total Suspended Solids	3.2	mg/L
LT3 I5-2 8/2/2017	002	Total Suspended Solids	3.2	mg/L
LT3 C3a-1 8/2/2017	003	Total Suspended Solids	8.9	mg/L
LT3 C3a-2 8/2/2017	004	Total Suspended Solids	27	mg/L
LT3 C3b-1 8/2/2017	005	Total Suspended Solids	6.2	mg/L
LT3 C3b-2 8/2/2017	006	Total Suspended Solids	5.3	mg/L

--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020239  
DATE OF ISSUE : 14 February 2017 PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 10 Feb 2017  
Received Date : 10 Feb 2017  
Testing Period : 10 Feb 2017 to 14 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 10/2/2017	001	Total Suspended Solids	5.9	mg/L
LT3 I5-2 10/2/2017	002	Total Suspended Solids	5.9	mg/L
LT3 C3a-1 10/2/2017	003	Total Suspended Solids	19	mg/L
LT3 C3a-2 10/2/2017	004	Total Suspended Solids	17	mg/L
LT3 C3b-1 10/2/2017	005	Total Suspended Solids	7.1	mg/L
LT3 C3b-2 10/2/2017	006	Total Suspended Solids	7.5	mg/L

--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

Susan, Wai-shan Ko  
Senior Chemist



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO.	: N17020257	PAGE	: Page 1 of 1
DATE OF ISSUE	: 15 February 2017		

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 13 Feb 2017  
Received Date : 13 Feb 2017  
Testing Period : 13 Feb 2017 to 15 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 13/2/2017	001	Total Suspended Solids	<2.5	mg/L
LT3 I5-2 13/2/2017	002	Total Suspended Solids	<2.5	mg/L
LT3 C3a-1 13/2/2017	003	Total Suspended Solids	14	mg/L
LT3 C3a-2 13/2/2017	004	Total Suspended Solids	14	mg/L
LT3 C3b-1 13/2/2017	005	Total Suspended Solids	4.1	mg/L
LT3 C3b-2 13/2/2017	006	Total Suspended Solids	4.2	mg/L


--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

  
Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020309  
DATE OF ISSUE : 17 February 2017 PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 15 Feb 2017  
Received Date : 15 Feb 2017  
Testing Period : 15 Feb 2017 to 17 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 15/2/2017	001	Total Suspended Solids	13	mg/L
LT3 I5-2 15/2/2017	002	Total Suspended Solids	17	mg/L
LT3 C3a-1 15/2/2017	003	Total Suspended Solids	30	mg/L
LT3 C3a-2 15/2/2017	004	Total Suspended Solids	39	mg/L
LT3 C3b-1 15/2/2017	005	Total Suspended Solids	16	mg/L
LT3 C3b-2 15/2/2017	006	Total Suspended Solids	13	mg/L

--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

Kenneth, Kar-kin LAM  
Senior Lab. Manager





# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020371  
DATE OF ISSUE : 21 February 2017 PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 17 Feb 2017  
Received Date : 17 Feb 2017  
Testing Period : 17 Feb 2017 to 21 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 17/2/2017	001	Total Suspended Solids	9.7	mg/L
LT3 I5-2 17/2/2017	002	Total Suspended Solids	11	mg/L
LT3 C3a-1 17/2/2017	003	Total Suspended Solids	17	mg/L
LT3 C3a-2 17/2/2017	004	Total Suspended Solids	16	mg/L
LT3 C3b-1 17/2/2017	005	Total Suspended Solids	10	mg/L
LT3 C3b-2 17/2/2017	006	Total Suspended Solids	11	mg/L


--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

  
Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020406  
DATE OF ISSUE : 22 February 2017  
PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 20 Feb 2017  
Received Date : 20 Feb 2017  
Testing Period : 20 Feb 2017 to 22 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 20/2/2017	001	Total Suspended Solids	4.8	mg/L
LT3 I5-2 20/2/2017	002	Total Suspended Solids	4.7	mg/L
LT3 C3a-1 20/2/2017	003	Total Suspended Solids	11	mg/L
LT3 C3a-2 20/2/2017	004	Total Suspended Solids	12	mg/L
LT3 C3b-1 20/2/2017	005	Total Suspended Solids	11	mg/L
LT3 C3b-2 20/2/2017	006	Total Suspended Solids	13	mg/L

--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020479  
DATE OF ISSUE : 24 February 2017  
PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 22 Feb 2017  
Received Date : 22 Feb 2017  
Testing Period : 22 Feb 2017 to 24 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 22/2/2017	001	Total Suspended Solids	14	mg/L
LT3 I5-2 22/2/2017	002	Total Suspended Solids	14	mg/L
LT3 C3a-1 22/2/2017	003	Total Suspended Solids	24	mg/L
LT3 C3a-2 22/2/2017	004	Total Suspended Solids	25	mg/L
LT3 C3b-1 22/2/2017	005	Total Suspended Solids	11	mg/L
LT3 C3b-2 22/2/2017	006	Total Suspended Solids	9.5	mg/L

--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020508  
DATE OF ISSUE : 28 February 2017 PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 24 Feb 2017  
Received Date : 24 Feb 2017  
Testing Period : 24 Feb 2017 to 28 Feb 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 24/2/2017	001	Total Suspended Solids	5.9	mg/L
LT3 I5-2 24/2/2017	002	Total Suspended Solids	6.0	mg/L
LT3 C3a-1 24/2/2017	003	Total Suspended Solids	12	mg/L
LT3 C3a-2 24/2/2017	004	Total Suspended Solids	13	mg/L
LT3 C3b-1 24/2/2017	005	Total Suspended Solids	21	mg/L
LT3 C3b-2 24/2/2017	006	Total Suspended Solids	22	mg/L


--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

  
Kenneth, Kar-kin LAM  
Senior Lab. Manager



# ENVIRO LABS LIMITED

Rm. 510 & 611-612, Hong Leong Plaza, 33 Lok Yip Rd., Fanling, N.T., H.K.

Tel: (852) 2676 2983 Fax: (852) 2676 2860

e-mail: [ell@envirolabs.com.hk](mailto:ell@envirolabs.com.hk) website: <http://www.envirolabs.com.hk>

## TEST REPORT

JOB NO. : N17020528  
DATE OF ISSUE : 01 March 2017 PAGE : Page 1 of 1

### 1. Customer

Enovative Environmental Service Limited  
Room 811, Hin Pui House,  
Hin Keng Estate,  
Tai Wai, Shatin, N.T., Hong Kong  
Attn.: Mr. Thomas Wong

### 2. Sample Identification

Sample Description : Six batch(es) of water samples said to be discharge water were submitted by the customer and received at the laboratory in ambient condition.  
Sampling : Conducted by the customer.  
Sampling Date<sup>a</sup> : 27 Feb 2017  
Received Date : 27 Feb 2017  
Testing Period : 27 Feb 2017 to 01 Mar 2017

### 3. Test Methods

Parameters	Reference Methods	Limits of Reporting
Total Suspended Solids dried at 103-105°C	APHA <sup>b</sup> 17e 2540 D	2.5 mg/L

### 4. Test Results<sup>c</sup>

Sample I.D. marked by the customer	Sample No.	Parameters	Test Results	Units
LT3 I5-1 27/2/2017	001	Total Suspended Solids	15	mg/L
LT3 I5-2 27/2/2017	002	Total Suspended Solids	15	mg/L
LT3 C3a-1 27/2/2017	003	Total Suspended Solids	39	mg/L
LT3 C3a-2 27/2/2017	004	Total Suspended Solids	37	mg/L
LT3 C3b-1 27/2/2017	005	Total Suspended Solids	8.6	mg/L
LT3 C3b-2 27/2/2017	006	Total Suspended Solids	9.4	mg/L


--- END OF REPORT ---

<sup>a</sup> Information is provided by the customer

<sup>b</sup> APHA Standard Methods for the Examination of Water and Wastewater, AWWA

<sup>c</sup> Test results relate only to the items received

APPROVED SIGNATORY:

  
John Chi-wai YAU  
Assistant Lab. Manager